



**STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
COLUMBIA ENVIRONMENTAL FIELD OFFICE
DIVISION OF WATER RESOURCES
1421 HAMPSHIRE PIKE
COLUMBIA, TENNESSEE 38401
PHONE (931) 380-3371 STATEWIDE 1-888-891-8332 FAX (931) 380-3397**

General approval is hereby granted for Lot 1 as defined in the Tisha Verhoef Division (Tom Osborne Road). The following shall be defined as general restrictions and shall apply to all lots with specific restrictions on each lot following general restrictions.

General Restrictions: Prior to any construction of a structure, permanent or mobile, the plans for the exact house/structure location and the subsurface sewage system must be approved by the Environmental Specialist with the Division of Ground Water Protection in Maury County. Any cutting or filling after revised mapping completed March 27, 2024, may render the site unsuitable. Drainageways, gullied areas, cut and fill material and disturbed soil areas are unsuitable for sewage disposal areas. Structures must be properly located to obtain gravity flow to drainfield or a pump will be required. Water taps, waterlines and driveways should be located at side property lines unless otherwise noted. The High Intensity Soils Map designating suitable soil areas for this subdivision is on file at the Environmentalist's office.

S.S.D.S. denotes Subsurface Sewage Disposal System.

Lot 1: Suitable soil for subsurface sewage disposal system is located on the northeastern portion of lot. With proper structure, driveway and utility locations outside of useable soils area, lot can accommodate a structure not to exceed four bedrooms.

Date

Alan Floyd
Environmental Specialist

AF/AJ